



NOTES:

1. ROOF DRAIN SHALL PROVIDE POSITIVE FLOW FROM DOWNSPOUTS (DS) TO YARD DRAINS.
2. YARD DRAINS SHALL BE INSTALLED UPSTREAM OF EACH DOWNSPOUT INFILTRATION TRENCH IN ACCORDANCE WITH STD DETAIL 02.05.02.
3. TRENCH BOTTOM SHALL BE A MINIMUM OF 1' ABOVE SEASONAL HIGH GROUNDWATER OR IMPERMEABLE SOIL LAYER.
4. TRENCH SHALL BE DESIGNED IN ACCORDANCE WITH SECTION 210.2.
5. INFILTRATION TRENCH SHOULD NOT BE INSTALLED UNDER IMPERVIOUS SURFACES.
6. CLEANOUT(S) SHALL BE INSTALLED IN ACCORDANCE WITH STD DETAIL 02.01.09.
7. NON-WOVEN GEOTEXTILE TO CONFORM TO WSDOT 9-33.2(1), TABLE 1 AND 2.



CITY OF PUYALLUP
PUBLIC WORKS AND DEVELOPMENT ENGINEERING



DOWNSPOUT INFILTRATION TRENCH

SCALE NTS	DATE REVISED: 05/19/2023	CITY STANDARD
FILE NAME: Y:\Shared\Drawings\City Standards\2018\02 - PART 2 - STANDARD DETAILS\CAD\200\02.05.01		02.05.01