



NOTES:

1. TRAFFIC APPLICATIONS SHALL BE HS-20 RATED, NOT FOR USE IN PUBLIC RIGHT-OF-WAY, PUBLIC EASEMENTS, OR TRACTS.
2. 18" SOLID LOCKING DUCTILE IRON FRAME AND COVER BY NYLOPLAST - TYPE C OR APPROVED EQUAL.
3. DUCTILE IRON FRAME AND COVER SHALL BE DRILLED AND TAPPED WITH 5/16" - 8 ZINC-PLATED HEX BOLT 1 1/8" LONG.
4. DUCTILE IRON FRAME AND COVER SHALL BE FLUSH WITH FINISHED GRADE.
5. STORM PIPE AND STRUCTURE BEDDING AND BACKFILL SHALL CONFORM TO STD DETAIL 06.01.01.
6. ALL BOLT HOLES DRILLED IN THE STRUCTURE SHALL BE WATERTIGHT WITH RUBBER SEALING WASHERS OR APPROVED EQUAL.
7. ALL PIPE JOINTS SHALL BE WATERTIGHT.
8. A CONCRETE FOOTING SHALL BE PROVIDED AT THE BASE OF THE STRUCTURE WHEN THE BOTTOM ELEVATION OF THE STRUCTURE IS WITHIN 6" OF HIGH GROUNDWATER.
9. THE MAXIMUM DEPTH FROM FINISHED GRADE TO THE PIPE INVERT IS 5'-0".



CITY OF PUYALLUP
 PUBLIC WORKS AND DEVELOPMENT ENGINEERING



YARD DRAIN

SCALE: NTS	DATE REVISED: 12/05/2022	CITY STANDARD
FILE NAME: Y:\Shared\Drawings\City Standards\2018\02 - PART 2 - STANDARD DETAILS\CAD\200\02.05.02		02.05.02