


**NOTES**

1. TRANSITION ZONE
  - a. 1-INCH GRADE CHANGE FROM EDGE OF SIDEWALK, CURB AND/OR OTHER HARD SURFACE.
  - b. 2% MAX. SLOPE.
  - c. TRANSITION SHALL BE A MINIMUM 18" AND INCLUDED T5.13 AMENDED SOILS PER BMP OR PER NOTE 3.
2. 24-INCH MINIMUM REQUIRED WHERE ADJACENT TO PARKING.
3. AVOID COMPACTION OF EXISTING SUBGRADE BELOW FACILITY.
4. SCARIFY SUBGRADE 3-INCHES MINIMUM BEFORE BIORETENTION SOIL MEDIA INSTALLATION.
5. PLANTINGS PER STANDARD DETAIL 02.07.05 AND PLANS.
6. BIORETENTION CELLS ADJACENT TO PARKING SHALL BE SPACED TO ALLOW PEDESTRIAN ACCESS TO VEHICLES EVERY 30 FEET, AT MINIMUM.
7. SIZING AND DESIGN OF FACILITY PER SWMMWW.
8. FREEBOARD DEPTH VARIES (2-INCHES OR 6-INCHES) DEPENDING UPON SIZE OF DRAINAGE FOR FREEBOARD, PONDING AND OVERFLOW DEPTH, SEE SWMMWW.
9. OVERFLOW TYPE DEPENDS ON PROJECT DESIGN. SEE STANDARD DETAIL 02.07.03.
10. INLET ELEVATION SHALL BE ABOVE FREEBOARD ELEVATION.



**CITY OF  
PUYALLUP**  
OFFICE  
of  
THE CITY ENGINEER

**BIORETENTION SECTION**

<b>DRAWN BY</b> V STOCKMAN	<b>CHECKED BY</b> TED HILL	<b>APPROVED BY</b> MARK PALMER	<b>REVISED BY</b> X	<b>DATE REVISED:</b> XXXXXX XXXXXX XXXXXX	<b>CITY STANDARD</b>
<b>FILE NAME</b> E:\DWG\COMMON\STDS\CITY\STDS\02_SD\02.07\02.07.01		<b>DATE APPROVED</b> 02/27/2017	<b>SCALE</b> NTS	<b>DATE</b> XXXXXX	<b>STANDARD</b> 02.07.01